


Himachal Pradesh
Public Works Department
BUILDING SAFETY CERTIFICATE

The building of **Jaypee Public School JSS Parisar, V.P.O. Samirpur, Tehsil Tauni Devi, Distt. Hamirpur (H.P.)** has been visually inspected by the concerned Junior Engineer (Civil) of this Sub-Division. As per visual inspection report of Junior Engineer the building seems to be safe at present only. The **School Building Safety Certificate** is hereby issued keeping in view of following points as given below:-

1. No earth quake resistant norms have been adopted during the construction/establish of building. Hence the structural safety of this building can't is ensured specially from earthquake point of view.
2. The building structure is R.C.C. framed structure and the constructional specifications/design are unknown the department.
3. The structure drawing is not approved by the competent Government Agency.

Note:- 1. This department will not be responsible for any loss of life and property etc. if this structure falls under any circumstances.
2. As per affidavit supplied by the concerned school the year of construction of school building is **2012** and however by present condition and as per visual inspection the **school building seems safe for running the school during academic session 2023-28** under normal conditions. As per Superintending Engineer (Works) HPPWD Nigam Vihar Shimla 02 office letter No.PW/WPC483/2004/Supreme Court Matter/WS-2021-1446-61 dated 16/6/2021.


Assistant Engineer,
Samirpur Sub Division,
HP.PWD., Samirpur.


Executive Engineer
Bhoranj Division
HPPWD Bhoranj