



## Single Window Clearance System

Directorate of Industries(DOI)  
Govt. of Himachal Pradesh

### DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

## NO OBJECTION CERTIFICATE

### TO WHOM IT MAY CONCERN

That the premises of **JAYPEE PUBLIC SCHOOL VPO TEH. TAUNI DEVI DISTT HAMIRPUR HP** was inspected on 2022-12-29 with reference to his application No. App/09/13/22/8/726 dated 2022-09-13 12:31:01 by the incharge Fire Station FS Hamirpur with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years w.e.f. **03/01/2023 to 02/01/2025** subject to fulfilment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire services.
4. Good House keeping must be maintained within the premises.

हिमाचल प्रदेश सरकार

**Remarks: Adequate Fire precautionary measures be adopted in consultation with local Fire Officer during annual day function or any other function where temporary structures and Pandals are to be erected.**

[Digitally Signed 03-01-2023 16:11:18]

**Chief Fire Officer.**  
Himachal Pradesh Shimla-2

Place: Shimla  
Dated: 2023-01-03

**PRINCIPAL**  
**JAYPEE PUBLIC SCHOOL**  
**JSS PARISAR V.P.O SAMIRPUR**  
**TEH. TAUNIDEVI, DISTT HAMIRPUR-177601 (HP)**

**Manager**  
**Jaypee Public School**  
**JSS Parisar, V.P.O. Samirpur**  
**Tehsil Taunidevi**  
**District Hamirpur (HP)-177601**